

**Roof Replacement  
Debert Aviation Centre  
266 Ventura Drive, Debert, Nova Scotia**

1. Instruction to Tenderers .1 Note the inclusion of this addendum on the Tender Form (Section 00 41 43, Article 2.3)
  
2. Spec. Section 07 00 00, Article 1.3.1 .1 Add the following under Existing Conditions:

Presence of Hazardous Materials:

The existing siding on the building exterior walls may contain asbestos. This siding was not tested but appears to be the same as the asbestos cement siding that was previously removed in another part of the building.

All asbestos containing materials removed from the site for disposal **MUST** be disposed of at the Colchester Waste Management Park, GroundFix Remediation Services site located in Kempton unless otherwise directed by the Engineer. All other hazardous demolition materials must be sent to approved and licensed facilities.

Bidders must include in their submission, the provision for proper removal and disposal of this hazardous material, should they deem it necessary as part of the roof replacement.

\*\*\*\*\* **END OF ADDENDUM #1** \*\*\*\*\*