

TENDER
TATAMAGOUCHE SEWER REPLACEMENT

Project #2502-1449

ADDENDUM #1

April 28, 2025

1. The following question was received and answered:

- A. Question: *It appears that the proposed sewer main is running at approximately the same elevation as the existing. If existing service laterals are encountered on the north side of the proposed main, is it expected that the contractor will tie these directly into the new main prior to testing or would the County rather lower the new main so that the top of the new main is below the invert of the existing? This would allow north side services to remain active and tied into the existing main until the new main has been tested and ready for hookups.*

Answer: *Where required, the Municipality will lower the alignment of the new sewer main by approximately 300mm to allow the existing laterals to remain in service prior to testing. This design change will be reflected in the IFC Drawings. Contractors shall account for this adjustment and include it in the cost of the sewer pipe installation.*

- 2. Tender Closing will not change as a result of this addendum; it remains as 3:00PM on May 2nd, 2025.**