

REQUEST FOR PROPOSALS
Construction Services
Biosolids Facility Aeration Upgrades
Project #2504-1504

ADDENDUM #2

Issued June 08, 2026

1.2 Proposal Submission

The Closing Date of the Request for Proposals has been changed from 3:00PM (local time), Wednesday, June 10, 2026, to **3:00PM (local time), Wednesday, June 17, 2026.**

3.1 Background Information

Blower Controls

Blowers will be controlled by the existing pressure transducers, coordination with Bélanger for PCL, VT Scada integration will be required.

The Municipality wishes to secure pricing on these additional items:

1. Installation of conduit for future replacement of level pressure transducers while tanks are empty for the placement of process piping.
2. Replacement of the existing High- and Low-level floats in all three tanks with Xylem floats.

Diffusers and Lateral Air Piping

Delete *Table 3.1.3: Summary of Diffuser Parameters* from RFP and replace with the following:

Table 3.1.3: Estimated Air Requirements

| Parameter | Value |
|-------------------------------------|--------------------------------------|
| Type | Fine Bubble |
| Sludge Holding Tank air requirement | 13.4 m ³ /min (474 SCFM) |
| Digester 1 air requirement | 16.8 m ³ / min (592 SCFM) |
| Digester 2 air requirement | 16.8 m ³ / min (592 SCFM) |

The quantity of diffusers should be as required to meet the estimated Air demands in tale 3.1.3.

END OF ADDENDUM #2